

System Usage	2025	2024
January	5,700,000	5,480,000
Daily Average	183,870	176,774
Max Daily	290,000	300,000
Year to Date	5,700,000	5,480,000

1. All backflow testing for January is done.
2. We finished flow tests with GZA. Monitoring equipment has been left in place. They will be back to collect the data and equipment at a later date.
3. Rod and Jon did six, meter change outs last month.
4. A&D Instruments programmed the high chlorine alarm for the booster station. We are now working on getting the chlorine system up and running.

Workload

Backflow Testing
Meter Change Outs
Service Line Inventory

Respectfully Submitted,

Rob Thorp